## T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690


Model No.


B-0674-CR-BSTR


Item No.


Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

	This Space for Archite
<u> </u>	Job Name
ADA Compliant	Model Specified
	Customer/Wholesaler









**Product Specifications:** 

8" Wall Mount Service Sink w/ Inlet Stops, Quarter-Turn Cerama Cartridges w/ Check Valves, Spout w/ Garden Hose Male Outlet, Rough Chrome Finish, Lever Handles, 1/2" NPT Vacuum Breaker & 1/2" NPT Female Inlets

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) ASSE 1001 (VB)

Drawn: TRK Checked: JMD Approved: Date: 04/16/24 Scale: Sheet: 1 of 2



## T&S BRASS AND BRONZE WORKS, INC.


2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690 Model No.

B-0674-CR-BSTR

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

	ITEM NO.	SALES NO.	DESCRIPTION
	1	000270-25	Rough Chrome Spout w/ Garden Hose Outlet
	2	012446-25NS	Quarter-Turn Cerama Cartridge, RTC w/ Check Valve, Handle, Index & Screw
	3	012394-25NS	Quarter-Turn Cerama Cartridge, RTC w/ Check Valve
	4	001638-45NS	Lever Handle (New Style)
	5	001193-19NS	Red Button Index, Press-in
	6	B-0969	1/2" NPT Vacuum Breaker
	7	018506-19NS	Blue Button Index, Press-in
	8	000925-45	Lab Handle Screw
	9	012447-25NS	Quarter-Turn Cerama Cartridge, LTC w/ Check Valve, Handle, Index & Screw
	10	012395-25NS	Quarter-Turn Cerama Cartridge, LTC w/ Check Valve
	11	002534-25	Close Nipple, 1/2" NPT
	12	00AA	1/2" NPT Female Eccentric Flange
	13	001019-45	Coupling Nut Washer
	14	163A	Built-in Service Stop



**Product Specifications:** 

8" Wall Mount Service Sink w/ Inlet Stops, Quarter-Turn Cerama Cartridges w/ Check Valves, Spout w/ Garden Hose Male Outlet, Rough Chrome Finish, Lever Handles, 1/2" NPT Vacuum Breaker & 1/2" NPT Female Inlets

Product Compliance:

ASME A112.18.1 / CSA B125.1 NSF 61 - Section 9 NSF 372 (Low Lead Content) ANSI A117.1 (ADA) ASSE 1001 (VB)

Drawn: TRK Checked: JMD Approved: JHB Date: 04/16/24 Scale: NTS Sheet: 2 of 2