

Electronic Faucets


TAG:

5EF-1D-DG-4DPWS

Electronic Sensor Faucet

Architect/Engineering Specifications:

Single hole deck mount electronic sensor faucet with polished chrome plated brass body, 4" c/c forged deck plate and 5 5/8" rigid gooseneck, 1.5 GPM vandal resistant aerator, AC/DC control module, mechanical mixing valve with integral check valves and 18" flexible stainless steel supply hoses with 3/8" compression connections. Certified to ASME A112.18.1/CSA B125.1, NSF 61-Section 9, NSF 372, UL 1951 and EPA WaterSense. Meets ADA ANSI/ICC A117.1 requirements




Features & Benefits:

- Single hole deck mount faucet w/ polished chrome plated brass body
- 4" c/c forged deck plate w/ gasket & mounting hardware
- 5 5/8" rigid gooseneck
- 1.5 GPM vandal resistant aerator, Series 6 (B-0199-06-WS)
- Water resistant control module
- Plug in AC transformer or (4) AA battery (DC) power options
- Mechanical mixing valve w/ integral check valves
- 18" flexible stainless steel supply hoses w/ 3/8" compression connections
- Low battery LED indicator light
- Material: Polished chrome plated brass body, deck plate & tubular spout

Product Compliance:









UL 1951

EPA WaterSense



Warranty: One Year (Limited)

Performance Data:

Pressure: 20 - 125 psi [1.38 - 8.62 bar]

Temperature: 40°F - 140°F [4.44°C - 60°C]

Flow Rate: 1.5 GPM [5.6 L/min] @ 60 psi [4.14 bar]

Water Consumption: @10 sec = .25 gal [.95 L]

@15 sec = .38 gal [1.44 L]

Optional Outlets	s (Series 4	/ VR Series 9)
------------------	-------------	----------------


GPM	Aerated	Non-Aerated (Laminar)		VR Non-Aerated (VR Laminar)	Optional Deck Plates
0.35	N/A	□ B-0199-04-N035	N/A	□ B-0199-09-N035	☐ 4" Chrome Plated Brass Deck Plate (Standard)
0.5	N/A	□ B-0199-04-N05	N/A	□ B-0199-09-N05	□ 8" Chrome Plated Brass Deck Plate
1.0	N/A	N/A	N/A	□ B-0199-09-LF10	
1.2	□ B-0199-04-F12	2 N/A	□ B-0199-09-F12	N/A	
1.5	□ B-0199-04-WS	N/A	Standard	□ B-0199-09-LF15	
2.2	□ B-0199-04	□ B-0199-25	□ B-0199-09	□ B-0199-27	











Date: 12/29/23